



Government Of West Bengal
Office Of The Divisional Fire Officer, Birbhum
West Bengal Fire & Emergency Services
Lalkhuti Para, Suri, Birbhum, Pin:- 731101

Memo no.: IND/WB/FES/20192020/81655

Date: 02-06-2023

From:

Divisional Fire Officer, Birbhum
West Bengal Fire & Emergency Services

To: SNEHALATA PUBLIC SCHOOL

PLOT NO- 6005/7397, KH NO- 3705, JL NO- 20, MOUZA- KIRNAHAR, PS- NANOOR, DIST- BIRBHUM

Sub: Renewal of Fire Safety Certificate for the existing construction of G+2 storied building under group Educational occupancy, in favour of "SNEHALATA PUBLIC SCHOOL" Bolpur Road, Kirnahar, PLOT NO- 6005/7397, KH NO- 3705, JL NO- 20, MOUZA- KIRNAHAR, PS- NANOOR, Pin- 731302, Dist- Birbhum.

This is in reference to your application no. 0125191231700073 dated 24-05-2023 regarding the Renewal of Fire Safety Certificate for the existing construction of G+2 storied building under group Educational occupancy, in favour of "SNEHALATA PUBLIC SCHOOL" Bolpur Road, Kirnahar, PLOT NO- 6005/7397, KH NO- 3705, JL NO- 20, MOUZA- KIRNAHAR, PS- NANOOR, Pin- 731302, Dist- Birbhum.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

Recommendation:

1. Driveway must be free of any type of obstruction for easy movement of fire appliances. No parking will be allowed on the drive way.
2. The interior finish decoration of the building shall be made low flame spread materials conforming I.S. specifications.
3. To eliminate risk of fire hazard, good housekeeping both for inside and outside of the building shall be strictly maintained.
4. A fire control room including a closed-circuit TV system will have to be maintained which observe all floor of the building.

A crew of trained Fireman under the experienced officer shall be maintained round the clock for safety of the building.

6. If required old line shall have to be replace with new lines, the cables shall always be laid in M.S conduit pipes continuously bonded to the earth.

7. Periodical flushing of water in the hydrant and sprinkler pipe line shall be made to maintain the efficiency working performance of above-mentioned system.

8. Fire License shall have to be obtained for storing and processing with L.P.G. and other highly combustible articles.

9. Existing electrical wiring of the whole building shall have to be carefully checked for any were and tear in them, particularly lines above false ceiling and ducts.

10. Transformer and switchgear room shall be protected with automatic co2 or DCP fire extinguisher conforming I.S specification.

11. First aid firefighting system shall be provided as per I.S specification.

12. The notice of firefighting and evacuation from the building shall be prepared and displayed at all vulnerable place of the building.

13. The employees and security staff shall be conversant with installed Fire Fighting equipment's of the building and to operate in the event of Fire and Testing.

14. Mock Fire practice and evacuation drill shall be performed periodically with participation of all occupants of building.

15. Arrangement shall be made for regular checking, testing and proper maintenance of all the Fire Safety installation and equipment's installed in the building to keep them in perfectly good working conditions at all times.

16. The Renewal of Fire Safety Certificate is valid for a period of three years from the date of issue, and has to be renewed after three years certifying about the satisfactory services, performance of all the Life and Fire Safety arrangements installation of the building.

Suryendu Sar.
Principal
Snehalata Public School
Kirnahar, Birbhum

Kithu Lal
Manager
Snehalata Public School
Kirnahar, Birbhum

Signature valid

Digitally Signed
Name: AMALES BARUI
Date: 02-Jun-2023 14:07:56
Reason: Approved
Location: West Bengal

Divisional Fire Officer, Birbhum
West Bengal Fire & Emergency Services

Government of West Bengal

Office of the Officer-In-Charge

Bolpur Fire Station, Bolpur,

Birbhum, PIN- 731204 ,

Email: bolpurfirestation@gmail.com


Phone: 03463 - 252301

TO WHOM IT MAY CONCERN

This is to certify that The entrance and the approach road to the **SNEHATALA PUBLIC SCHOOL, kirnahar bolpur road, Birbhum, West Bengal, Pin:-731302** is wide enough for free and smooth access by emergency vehicles/fire engines as per norms of West Bengal Fire and Emergency Services.

Date:- 07/03/2024

Signature


07/03/24
Officer In charge
Bolpur Fire Station
Bolpur, Birbhum
W.B.F & E.S



Principal
Snehalata Public School
Kirnahar, Birbhum


Manager
Snehalata Public School
Kirnahar, Birbhum



FIRE SAFETY CERTIFICATE

APPENDIX-XII

RECTIFIED COPY

No. FSR/012518621171130

Date: 23/03/2024

Certified that the Snehalata Public School (name of the building premises) at Bolpur Road, Village: Kirnahar, Sub division: Bolpur, Dist: Birbhum, West Bengal pin: 731302 (Address) comprised of Academic Building Block - Ground Floor, 1st Floor, 2nd Floor and Annexure Block - Ground Floor owned and occupied by Snehalata Public School (name of the institution) have complied with the fire prevention and fire safety requirements in accordance with rule of State/ UT Fire Service Rules, and verified by the officers concerned of Fire Service on 28/02/2024 (date of inspection in the presence of Ms. Mithu Pal, Manager, Kirnahar, Purbapatty, Birbhum, West Bengal, Pin: 731302 (name and address of the Manager/Secretary or his representative) and that the building/ premises is fit for occupancy up to classes x (X /XII) with effect from 4/03/24 for a period of 03 (Three) years in accordance with rule and subject to compliance of specific conditions as appended :-

1. Issued in the RFSC vide
2. Memo NO IND/WB/FES/201920/81774
- 3.
- 4.

Issued on 23/03/2024 (Date of issue) at D.F.O Birbhum Div, WB F&ES (place) by

*Strike out whichever is not applicable.

Signature with Seal

Name

Designation

Name and Address of Department /Office.....

[Signature]

Deputy Director

West Bengal Fire & Emergency Services,
North Zone, Suri, Birbhum

SWITCH HOUSE

TO

Snehalata Public School
Bolpur Road, Village: Kirnahar
Sub division: Bolpur, Dist: Birbhum,
Pin- 731302, West Bengal
(Name & Address of the Institution)

[Signature]
Principal
Snehalata Public School
Kirnahar, Birbhum

[Signature]
Manager
Snehalata Public School
Kirnahar, Birbhum

ENDORSEMENT

The No Objection Certificate issued by Fire Service stand cancelled and annulled due to

(Reasons to be recorded)

(Name and designation of the authorized signatory)

*The filled up certificate should be either in Hindi or English, If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single PDF